

BID # SDOC-05-052-CJ

January 14, 2005

**ADDENDUM NO.: 4
(To be attached and become a part of the Bid)**

FIRE ALARM PARTS & INSTALLATION

To be opened on January 19, 2005 at 2:00 p.m., in the School District of Osceola County, Purchasing Office, 817 Bill Beck Boulevard, Kissimmee, Florida 34744.

Clarification of an additional question submitted:

Question #1

Are engineer stamped/sealed and/or NICET level IV reviewed drawings required for all installation drawings?

Answer: Yes, All projects under \$5,000.00 require NICET level IV reviewed drawing submitted; all projects over \$5,000.00 require Engineer stamped drawings submitted.

Acknowledgement of Addendum by Vendor:

This addendum shall be completed by Vendor and returned with the Bid Package. If the Bid package has already been submitted, this addendum must be submitted to the above address in a sealed envelope, which is marked on the outside Addendum to Bid, Bid title and number.

This is to acknowledge receipt of this addendum, which will become part of the Bid document.

NAME (TYPED)

TITLE

SIGNATURE

VENDOR NAME